

# Impact of Water Losses on Pressure and Energy in MWA Trunk Main Network, Thailand

Adichai Pornprommin\*,

Surachai Lipiwattanakarn and Sutthisak Lapprasert

1

## Metropolitan Waterworks Authority (MWA)

Kanchanaburi

**Total Area 3,200 sq.km.**

**Service Area 2,500 sq.km.**

**Total population serve >10 million**  
**System Input Volume >5 MCM/day**

Pathumthani

**Nonthaburi**

**Bangkok**

Chachengsou

**Samutprakarn**

Samutsakorn


Ratchaburi

Samutsongkram


**Customer Service Connections  
> 2 million**

Chonburi

## 4 Water Treatment Plants (WTP) with 191-km transmission system




## Trunk Main Network



- D = 500-1,800 mm
- 1,700 km
- 4 WTPs
- 11 distribution pumping stations
- 6 valve chambers

# Simulation by EPANET software



5


# Energy Balance Concept

6

# No water loss (%WL = 0)

$$E_{input} = E_{deliver} + E_{friction}$$

$$\rho g Q h_{input} = \rho g Q h_{deliver} + \rho g Q h_{f0}$$




7

# %WL = 10% with a leak

$$E_{input} = E_{deliver} + E_{friction} + E_{leak}$$

$$1.1\rho g Q h_{input} = \rho g Q h_{10\%} + \sum \rho g Q h_f + 0.1\rho g Q h_{mid}$$



8

# Energy Balance Metric for MWA Trunk main network

$E_{\text{Input}}$ Input energy	$E_{\text{Output}}$ Output energy	$E_{\text{U,DM}}$ Energy delivered to DMs
		$E_{\text{L,DM}}$ Outgoing energy through water loss in DMAs
		$E_{\text{L,T}}$ Outgoing energy through water loss on trunk mains
	$E_{\text{Dissipated}}$ Dissipated energy	$E_{\text{F,DM}}$ Friction at the DM feed lines
		$E_{\text{F,T}}$ Friction on the trunk mains
		$E_{\text{F,V}}$ Friction at throttled valves

9

## 25.8% water losses in March 2013

Unit: MWatt-hr/day (%)

$E_{\text{Input}}$ Input energy 277 (100%)	$E_{\text{Output}}$ Output energy 148 (53.4%)	$E_{\text{U,DM}}$ Energy delivered to DMs 107 (38.6%)
		$E_{\text{L,DM}}$ Outgoing energy through water loss in DMAs 31 (11.2%)
		$E_{\text{L,T}}$ Outgoing energy through water loss on trunk mains 10 (3.6%)
	$E_{\text{Dissipated}}$ Dissipated energy 129 (46.6%)	$E_{\text{F,DM}}$ Friction at the DM feed lines 52 (18.8%)
		$E_{\text{F,T}}$ Friction on the trunk mains 64 (23.1%)
		$E_{\text{F,V}}$ Friction at throttled valves 13 (4.7%)

10



# MWA Targets in 2021

- To reduce %WL to 19% and
- raise the average pressure to 10.8 m.

11

## Scenario

Leakage is pressure-driven flow and the main component of water losses. Thus,

$$Q_{leak} = C_L P^{N_1}$$

Scenario	Scenario Explanation	Throttling valves	Water loss parameters
0	Base model from March 2013	Yes	$C_L$
1	Remove all throttled valves	No	$C_L$
2	1st step of leak reduction	No	$0.8 * C_L$
3	2nd step of leak reduction	No	$0.6 * C_L$
4	3rd step of leak reduction	No	$0.4 * C_L$

12

# Results

Scenario	Volume of water losses, WL (MCM/day)	Percentage of water losses, %WL (%)	Average Pressure (m)	Range of Pressure (m)	Input Energy, $E_{input}$ (MW-hr/day)
0	1.422	27.45	8.66	4.25 - 10.70	270
1	1.526	28.89	9.24	4.40 - 11.73	289
2	1.295	25.63	9.74	4.55 - 12.49	277
3	1.036	21.61	10.33	4.72 - 13.39	264
4	0.741	16.48	11.02	4.92 - 14.49	249

Thus, if the MWA could reduce %WL to 19% as its target, the pressure would raise to 10.7 m very close to the target (10.8 m) by itself.

13

## Conclusion

- If MWA removes all throttled valves and can find and fix leaks and reduce %WL to 19% as its target, the pressure will raise to its pressure target (10.8 m) without increasing its pressure at the sources.
- MWA will save water of 0.434 MCM/day.
- MWA will save electricity around 23 MW-h/day (excluding production & transmission).
- The electricity reduction is worth ~30 mil.Baht/year (900,000 USD/year).

14

# Thank you

15

## 0% water losses

Unit: MWatt-hr/day (%)

$E_{\text{Input}}$ Input energy 207 (100%)	$E_{\text{Output}}$ Output energy 137 (66.2%)	$E_{\text{U,DM}}$ Energy delivered to DMs 137 (66.2%)
		$E_{\text{L,DM}}$ Outgoing energy through water loss in DMAs 0 (0%)
		$E_{\text{L,T}}$ Outgoing energy through water loss on trunk mains 0 (0%)
	$E_{\text{Dissipated}}$ Dissipated energy 70 (33.8%)	$E_{\text{F,DM}}$ Friction at the DM feed lines 25 (12.1%)
		$E_{\text{F,T}}$ Friction on the trunk mains 37 (17.9%)
		$E_{\text{F,V}}$ Friction at throttled valves 8 (3.8%)

16